# TRAX

# **Transformer and Substation Test System**



- Replaces need for multiple test sets
- Saves time by eliminating need for multiple instruments learning
- User-friendly interface reduces training and testing time
- Portable and compact system components for easy shipping
- "State of the art" measurement methods for advanced diagnostic testing

## DESCRIPTION

TRAX is a multi-function test system for transformer substation testing. The test system replaces numerous individual testing devices which makes testing with TRAX a time saving and cost effective alternative to conventional measurements using separate instruments.

TRAX is a unique test system for testing power, distribution and instrument transformers, as well as a variety of other substation components. Providing up to 800 A (TRAX 280) and 2200 V (2000 A and 12 kV with accessories) with a frequency range adjustable from 5 Hz (1 Hz with tan delta unit) to 500 Hz, TRAX can be used with an integrated touch screen or external computer device with web browser.

Variable levels of voltage and current can be generated and measured with high precision, allowing TRAX to be used for a wide range of applications such as turns ratio, excitation current, winding and contact resistance, impedance, tan delta/power factor testing and various primary tests for LV, MV and HV electrical apparatus including but not limited to:

- Power & distribution transformers
- Instrument transformers
- Bushings
- LV, MV and HV circuit-breakers
- Busbars
- Protection relays
- Grounding systems

TRAX is designed to be a complete solution in transformer testing. With its 4800 VA power capability it is a high efficiency, high accuracy and excellent performance transformer test system.

## **Test capability**

- Winding resistance measurements
- Adaptive algorithm for optimized transformer demagnetization
- True dynamic resistance measurements on load tapchangers
- 250 V transformer turns ratio measurements
- 12 kV dissipation factor and capacitance testing features

The user interface allows fully manual control where the user defines a specific test setup. Alternatively, a variety of individual instruments/apps are available to perform automated testing procedures such as winding resistance, turns ratio, impedance measurements, relay testing, circuit breaker analysis and more. The tests can be organized and reported as separate tests or as a combined full set of test results for the same asset.

The compact, light-weight design, only 26 kg (TRAX 220), allows shipment in its transportation case within the limits of check-in luggage (32 kg)

### TRAX Transformer and Substation Test System

## **FEATURES AND BENEFITS**

- One unit multi function system for transformer/substation testing
  - Replaces need for multiple test sets
  - Saves time by eliminating need for multiple instruments learning
  - User-friendly interface reduces training and testing time
  - Portable and compact system components for easy shipping
- Outstanding flexibility for selecting output current or voltage signals for various tests
  - AC current up to 2000 A (with TCX 200)
  - DC current up to 100 A
  - AC voltage up to 12 kV (with TDX 120)
  - DC voltage up to 300 V
- State of the art measurement methods for advanced diagnostic testing, e.g.
  - 3-phase Power transformer measurements of:
    - » Turns ratio
    - » Winding resistance
    - Load tap-changer continuity, timing and dynamic resistance (patent pending)
    - » Excitation current
    - » Leakage reactance/short-circuit impedance
    - » Demagnetization
    - 3-phase transformer measurements without manual cable reconnections (with TSX300)
  - CT and VT testing
  - ▶ HV tan delta/power factor (with TDX 120)
- Compact and lightweight
  - 26 kg TRAX 220 (main unit), shipping weight <32 kg</p>
  - Smart cable technology for reducing cable weight

# **USER INTERFACE**

TRAX user interface architecture is based on a number of individual instruments/apps where only the necessary functionality is displayed by default. For manual testing a generic instrument is available where the user selects output, measurement inputs and how the data should be processed.

For testing complete components (e.g. power transformers), measurement results from multiple instruments can be collected and presented in one report.



#### Start screen



### **My TRAX**



# Transformer and Substation Test System

ft	Ê			Winding Resi P40 T1 training 20	istance 16-03-16 -	*	6	?
	Transf	omer. 111						
	YN HI	d11		Taps on	Primary	Generator		16.4
	Дно			Tap changer	OLTC .	Generator		
	H3 <sup>57</sup> TH2			Number of Taps		Test Current		10.00 A
~	Use Configurat	ion						
H1-H0			10.00 A	542.4 mΩ	99.98 %			
H2-H0			10.00 A	537.4 mΩ	99.98 %			
H2-H0		2	10.00 A	525.0 mΩ	100.0 %			
H2-H0			10.00 A	512.4 mΩ	99.99 %			
H2-H0		4	10.00 A	500.0 mΩ	99.99 %			
H2-H0			10.00 A	488.0 mΩ	99.99 %			
H2-H0		6	10.00 A	474.6 mΩ	100.0 %			
H2-H0			10.00 A	462.2 mΩ	99.99 %			
H2-H0		8	10.00 A	449.9 mΩ	100.0 %			
H2-H0			10.00 A	437.7 mΩ	99.98 %			
H2-H0		10	10.00 A	411.8 mΩ	100.0 %			
H2-H0			10.00 A	434.9 mΩ	99.99 %			
H2-H0			10.00 A	448.8 mΩ	100.0 %			
F				<b>/</b>		<u> </u>		
Wiı	nding	resi	stand	ce				

A Ê ..... Excitation Current P40 T1 training 2016-03-16 -1 ? 50 Hz Taps o Primary 80.00 V 92 020 V 67 980 V High Low Fre 1-H0 H1-H0 H1-H0 H1-H0 H1-H0 H1-H0 H1-H0 H1-H0 H1-H0 H1-H0 ti 📝 **Excitation current** 

			P40 11 trainin	ig 2016-0	3-16 -				•
T	ansformer. YNd11	Taps	on	Prir	nary +		Nominal Voltag	ges	
YN	d11					Primary		80.00	kV
			changer		OLTC +	Secondary		0.000	J KV
	не <sub>х</sub>	Num	ber of Taps				Test Voltage		
		High			92 020 V		aroux		
✓ Use Configura	ition	Low			67 980 V		250 V *		
Connection	Tap (P)	Tap Voltage	U	TTR	Measured TTR	Error	I Exc	Phase	
H1-H0 / X1-X3	19	67 980	249.4 V	5.947	5.973	0.44 %	3.730 mA	0.01	
H1-H0 / X1-X3		69 316	249.2 V	6.064	6.087	0.39 %	3.596 mA	0.01	
H1-H0 / X1-X3		70 651	249.3 V	6.180	6.202	0.35 %	3.468 mA	0.01 *	
H1-H0 / X1-X3		71 987	249.4 V	6.297	6.316	0.30 %	3.343 mA	0.01	
H1-H0 / X1-X3	15	73 322	249.2 V	6.414	6.431	0.26 %	3.226 mA	0.01	
H1-H0 / X1-X3		74 658	249.2 V	6.531	6.545	0.22 %	3.115 mA	0.01 *	
H1-H0 / X1-X3		75 993	249.3 V	6.648	6.660	0.18 %	3.010 mA	0.01 *	
H1-H0 / X1-X3		77 329	249.4 V	6.765	6.774	0.15 %	2.911 mA	0.01 *	
H1-H0 / X1-X3		78 664	249.3 V	6.881	6.889	0.11 %	2.816 mA	0.01	
H1-H0 / X1-X3		80 000	249.3 V	6.998	7.003	0.07 %	2.671 mA	0.01	
H1-H0 / X1-X3	9	81 336	249.2 V	7.115	7.118	0.04 %	2.584 mA	0.01	
<b>E</b>	. mi i								
	000	=/							

**(i)** 7

30

**Turns ratio** 

🖨 🗰



Continuous		A correct October A	ST ST
Continuous	Outp 0.	put current Vollage 0000 A 0.0000	R1
Current	Measured resistance	Voltage	
50.0 A	997.8 μ2	49.89 mV	
50.0 A	990.4 µM	49.92 mV	
50.0 A	998.3 uO	49.91 mV	
50.0 A	997.9 μΩ	49.89 mV	
50.0 A	997.9 μΩ	49.90 mV	
50.0 A	998.4 μΩ	49.92 mV	
50.0 A	998.4 μΩ	49.92 mV	
50.0 A	998.1 μΩ	49.91 mV	
	0		
	Current 1000A 500A 500A 500A 500A 500A 500A 500A 500A 500A 500A	Current         Measured resistance           300.0 A         998.4 μΩ           500.0 A         998.4 μΩ           500.0 A         998.3 μΩ           500.0 A         998.3 μΩ           500.0 A         998.3 μΩ           500.0 A         998.3 μΩ           500.0 A         997.9 μΩ           500.0 A         997.9 μΩ           500.0 A         998.4 μΩ	Current         Messured resistance         Voltage           00.0 A         998.4 μΩ         49.92 mV           50.0 A         998.4 μΩ         49.92 mV           50.0 A         998.3 μΩ         49.91 mV           50.0 A         998.3 μΩ         49.91 mV           50.0 A         998.3 μΩ         49.91 mV           50.0 A         997.9 μΩ         49.89 mV           50.0 A         997.9 μΩ         49.82 mV           50.0 A         997.9 μΩ         49.92 mV           50.0 A         998.4 μΩ         49.92 mV           50.0 A         998.4 μΩ         49.82 mV           50.0 A         998.4 μΩ         49.92 mV           50.0 A         998.1 μΩ         49.82 mV           50.0 A         998.1 μΩ         49.91 mV

**Contact resistance** 

# **APPLICATION**

A variety of voltage and current levels can be generated and measured with high precision which allows the multi-function test set to be used for a wide range of applications. Examples are:

- Power transformer
  - Ratio and phase
  - Winding resistance
    - » Single phase up to 100 A
    - » Three-phase/six windings up to 16 A
  - Tap changer testing (single-phase or three-phase)
    - » Continuity
    - » Dynamic current
    - » Dynamic voltage
    - » Dynamic resistance (new patent pending method)
  - Demagnetization (adaptive method for fast and efficient process)
  - Magnetic balance
  - Excitation current
  - Leakage reactance/short-circuit impedance
  - Zero-sequence impedance
  - Frequency response of stray losses (FRSL)
  - Tan delta/power factor with individual temperature correction (ITC) and voltage dependence detection (VDD)
  - Capacitance

### Current transformer

- Ratio, burden and polarity
- Phase and magnitude error
- Excitation curve (knee-point)
- Winding resistance
- Secondary burden
- Dielectric withstand voltage
- Voltage transformer
  - Ratio and polarity
  - Phase and magnitude error
  - Secondary burden
  - Dielectric withstand voltage
- Resistance testing
  - Contact resistance
  - ▶ DualGround<sup>™</sup> measurements
- Circuit breaker testing
  - Main and resistor contact timing
  - Motion
  - Operating voltage
  - Coil current
  - Contact resistance
- Primary testing
  - Circuit breakers
  - General primary injection tests
- Protection relays
  - Single phase testing of primary and secondary relays (> I, < I, > V, < V, > f, < f)</p>
- AC insulation testing
  - Tan delta/Power factor
  - Capacitance
  - Tip-up testing
  - 1-505 Hz frequency range

# **SPECIFICATIONS TRAX**

Specifications are valid at nominal input voltage and an ambient temperature of  $+25^{\circ}C \pm 5^{\circ}$ , (77°F). Specifications are subject to change without notice.

Evironment	
Application field	For use in high-voltage substations and industrial environments
Temperature	
Operating	-20°C to +55°C (-4°F to +131°F)
Storage	-20°C to +70°C (-4°F to +158°F)
Humidity	< 90%RH, non-condensing
CE- marking	l
ЕМС	2004/108/EC
LVD	2006/95/EC
General	
Mains input	100-240 V, 50/60 Hz (± 10%)
Input current	≤ 16 A continuous Short-term up to 30 A < 60 s
Main fuses	F1 and F2, 25 A
	TEST GROUND To be connected to the test object ground before connecting any other cables to the unit.
Ţ	GROUND For connecting an additional ground between the main unit and accessories or to ground exter- nal objects e.g. optional trolley
Dimensions	475 x 315 x 330 mm (excl. handles) (18.7" x 12.4" x 13")
Weight	
TRAX 219	25 kg (55 lbs)
TRAX 220	26 kg (57 lbs)
TRAX 280	30 kg (66 lbs)
Display	
Size	10.4″
Resolution	1024x768 XGA
Туре	TFT touch
Contrast ratio	1000:1
Brightness	1000 cd/m <sup>2</sup>

Outputs		
Item	Specification	Comment
0-2200 V <sub>AC</sub>	1 A, 1 min 0.2 A, >2 h 2500 VA (max) Frequency range: 5-70 Hz	The output is discon- nected with a relay and the output is "live" only when this generator is selected
0-250 V <sub>AC</sub> / 0-10 A <sub>AC</sub>	10 A, 1 min 20 A, max 10 s 2.5 A, >2 h Frequency range: 5-505 Hz	
0-200 A <sub>AC</sub>	200 A/6 V, 1 min 80 A, >2 h Frequency range: 45-70 Hz	TRAX220
0-800 A <sub>AC</sub>	0-800 A/6 V, 1 min 0-200 A/10 V, >2 h Frequency range: 45-70 Hz	TRAX280
0-16 A <sub>DC</sub>	16 A, continuous	
	1 A continuous	
0-300 V <sub>DC</sub>	10 A,1 minute 2.5 A, >2 h	Rectified DC. Intended to be used as e.g. auxiliary DC supply
0-100 A <sub>DC</sub>	100 A, 2 minutes 70 A, continuous	
DC output power	Max 1000 VA , con- tinuous Max 50 V compliance voltage	
Binary output	250 V/35 A (max) 2 x 0-10000 s	Output contacts for OLTC and circuit breaker operation with internal voltage and current measurements
AUX		
CONTROL	54 V DC	Ethernet communication and power to acces- sories.
POWER	0-235 V AC	Directly from power amplifier for powering accessories (TDX/TCX)
With TRAX TDX	12 kV AC 0-12 kV, 1 min 0-12 kV/300 mA, 4 min 0-12 kV/100 mA, continuous	
With TRAX TCX	2000 A AC 0-2000 A/2.4 V, 1 min 0-1000 A/4.8 V, 1 min	

Inputs		
ANALOG		
1234		
Current	4 x 0-10 A AC/DC	
Voltage	4 x 250/350 V AC/DC	
R1 R2	2 x 0-50 V DC	Intended for resistance measurements but can be used for AC voltage measurement up to 40 V RMS
TRANS		Input for analog trans- ducers and low level analog signals
TRIG IN		Contact or voltage sense
TIMING	3 x 0-10000 s	Binary inputs for timing measurements in timer and relay testing applica- tions. A and B inputs dedicated for Start and Stop.

### Calculated / displayed parameters

Arithmetic	+, -, *, /
Power	P, VA, Q, S
Impedance	R (DC), Z, Xp, Xs, Rs, Rp, Ls, Lp, Cs, Cp, phase

#### Derating at lower mains voltage

TRAX specification is valid at 230-240 V mains voltage. Output power is decreased at lower mains voltages.

Derating at high ambient temperature

TRAX specification is valid at  $23 \pm 5^{\circ}$ C. Max output current times will be reduced when using TRAX in high ambient temperature. **Derating at lower frequencies** 

TRAX voltage output specification is at 50 Hz. Maximum voltage output at lower frequencies is limited by the transformer. Derating is linear with frequency and max voltage output at 5 Hz is 10% of rated output.

### **Measurement accuracy**

External AC/DC voltage and current	0.05% of reading + 0.05% FS
Internal DC current	0.1% of reading + 0.1% FS
Internal AC current	0.2% of reading + 0.2% FS
Internal AC voltage	0.2% of reading + 0.2% FS
СОМ	
Ethernet port	For running the instrument from an external PC or connect it to an external network.
Connector for Wifi antenna	For running the instrument wireless from a PC or tablet. (Option)
USB	3 USB ports for multipurpose use

### TRAX

Transformer and Substation Test System

n	Art No	Item	
V 290	AIL NO.	Optional Accessories	
AC current output			
iternal touch screen			
1anual Control and Standard Transformer pack-		Soft light case	
vith the following apps:		Interlock foot switch	
Iding resistance with OLIC continuity		Green/red strobe box (flash light)	
nagrietization ns ratio		SW packages for extended instruments/	
tation current		apps	
ort-circuit impedance (leakage reactance)	AJ-19090	Advanced transformer	
X 220		SW package with the following apps:	
A AC current output		<ul> <li>Dynamic OLIC measurements (DRM)</li> <li>EBSL (frequency response of stray losses)</li> </ul>	
internal touch screen		<ul> <li>Magnetic balance</li> </ul>	
Vianual Control and Standard Transformer pack-			
vium une rollowing apps: oding resistance with OLTC continuity		CI/VI SW package with the following apps:	
nagnetization		CT ratio (with burden)	
ns ratio		<ul> <li>CT burden</li> </ul>	
itation current		<ul> <li>CT excitation curve (knee point)</li> </ul>	
rt-circuit impedance (leakage reactance)	AJ-19290	<ul> <li>Polarity</li> </ul>	
X 219		<ul> <li>CT ratio with voltage</li> </ul>	
A AC current output		<ul> <li>CT winding resistance</li> </ul>	
Manual Control		CI voltage withstand test	
ternal screen, remote control only	AJ-19390	CT ratio Rogowski	
ıded Accessories		VT ratio	
all models above)		• VT burden	
ins cable		<ul> <li>VT secondary voltage withstand test</li> </ul>	
und cable 10 m (33 ft)		Polarity	
cable set		<ul> <li>VT electronic</li> </ul>	
se cables 2 x 10 meter (33 ft)		Substation	
/in cables, 2 x 10 meter (33 ft)		SW package with the following apps:	
rent cables, 16 mm2, 2 x 10 m (33 ft)		<ul> <li>Circuit-breaker analyzer</li> </ul>	
(AAZ 19/220) rrent cables 50 mm2 2 x 6 m (20 ft) (TRAX 280)		<ul> <li>LV CB timing</li> </ul>	
' cables, 2 x 5 m (16 ft)		<ul> <li>Single-phase relay testing</li> <li>Timor</li> </ul>	
erlock Fixed, 2 m (6.5 ft)		Phase angle meter	
nper cable 5 meter (16 ft)		<ul> <li>Ground/earth/impedance</li> </ul>	
ernet cable		<ul> <li>Line impedance/K-factor</li> </ul>	
Standard package		Wattmeter	
isport case r Manual		Instruments	
		TRAX TDX 120 – High voltage unit for tan delta	
		capacitance and excitation current measurements.	
and the second		TRAX TCX 200 – High current accessory (cable +	
		booster) that can be placed close to the measure-	
	10	ment object for minimizing high current cable	
· · ·		length/weight when performing high current	
Megger;		primary testing up to 2000 A	
Date Internet	1	TRAVIEW 200 A HOUSE 12 HOUSE (C	

switchbox for automated turns ratio (250V), winding resistance (16A), excitation current, leakage reactance, FRSL and magnetic balance measurements AJ-69390

Other options e.g. SFRA/FRAX, DFR/IDAX, DC insulation/MIT offered as separate products if requested.

TDX120, high voltage unit (12 kV) for tan delta and capacitance measurements (optional accessory, AJ-69090).

POSTAL ADDRESS Megger Sweden AB Rinkebyvägen 19 SE-182 36 DANDERYD SWEDEN +46 8 510 195 00 seinfo@megger.com

#### TRAX\_DS\_en\_V07a

Art. No. ZI-AJ01E 
Doc.AJ0204GE 
2016
Subject to change without notice.

ISO 9001:2008 The word "Megger" is registered trademark www.megger.com

